



Battery Management System in Microgrid using LabView

Shreyanka Y H ¹, Sinchana T R², Vishwas H M ³, Lavanya N ⁴, Malini K V⁵,

Ramya K⁶

^{1, 2, 3, 4, 5, 6} Department of Electrical and Electronics Engineering, Sri Sairam College of Engineering, Bangalore.

¹SB22EE021, ²SB22EE022, ³SB22EE028, ⁴SB22EE016

ABSTRACT

Battery management systems (BMS) play a vital role in enhancing the efficiency and reliability of microgrids, especially with increasing reliance on renewable energy sources. This paper presents an innovative approach to battery management in microgrids using LabView software. The proposed system monitors, controls, and optimizes battery performances within a microgrid environment. Experimental results demonstrate Lab View's capability in real-time data acquisition, charge/discharge control, and fault detection. This approach offers an adaptable and cost-effective solution for efficient microgrid operation and implementations can expand this model's scalability and interoperability within larger energy networks.

Keywords: Battery management, Microgrid, LabVIEW, Renewable energy, Real-time monitoring.

1 Introduction

With the growth of renewable energy sources, the need for reliable energy storage systems has intensified. Microgrids, which can operate independently or in conjunction with the main grid, rely heavily on batteries to stabilize the energy supply. L. Roiné et.al.[1] A microgrid is a small-scale grid designed to provide power to local communities and be able to connect or disconnect from the main grid, is studied Efficient BMS is essential for managing charge cycles, balancing energy, and preventing overcharging or overheating, thus ensuring long term stability and safety of these systems. LabVIEW, a graphical programming environment, offers a flexible solution to monitor and control battery parameters in real time, addressing challenges in traditional microgrid battery management. C. Gordillo et.al. [2] Management System and Control (MSC) of DC-μG has been developed using National Instruments Company technology, generating MSC embedded into two NI myRIO-1900 hardware and using LabVIEW as programming language software. L. Guo et.al. [3] Developed a virtual environment using LabVIEW to provide a promising solution for integrating renewable energy sources and distributed power generation into the power grids. This concept was used in several engineering technology courses to teach topics including solar and wind power, data acquisition, DC-DC converters, battery management, and microgrids. P. Mahat et.al. [4] Optimized scheduling of a micro-grid battery storage system that considers the next-day forecasted load and generation profiles and spot electricity prices. P. Mahat et al. [4] enhanced



the scheduling of a micro-grid battery storage system by considering spot power prices and the demand and generation profiles predicted for the following day. I. Poonahela and others [5] an interactive monitoring interface that can show helpful power data throughout the microgrid and a microgrid system. The interactive interface of the system is designed using LabVIEW software, and power data is retrieved from a microgrid model created in a Matlab/Simulink environment. C. Ju et al. [10] to provide power dispatch based on hourly-ahead price and forecast data in the most economical manner possible, EMS converts the long-term installation cost into the short-term operational cost that accounts for real-time scheduling. This process incorporates the cost of battery degradation to the depth of charge and lifetime.

2 Recent Works

Research on battery management in microgrids has primarily focused on energy optimization and fault detection. Systems utilizing advanced hardware solutions often require significant resources, limiting their accessibility and scalability. LabVIEW's graphical interface simplifies complex tasks in monitoring and controlling BMS by integrating sensors, controllers, and user interfaces into a single environment. Recent studies have explored LabVIEW in applications ranging from renewable energy systems to grid management, highlighting its potential to enhance system efficiency and reliability.

3 Proposed Work Explanation

3.1 System Architecture

The proposed BMS integrates batteries, sensors, and a microcontroller with LabVIEW to provide a centralized monitoring and control system. The LabVIEW interface allows real time visualization of battery health metrics such as state of charge (SOC), voltage, and temperature. With this setup, the BMS can respond dynamically to fluctuations in load demand or battery status, optimizing charging and discharging cycles for improved energy efficiency and longevity. Additionally, LabVIEW's flexible design enables the implementation of automated control algorithms, ensuring that the battery operates within safe parameters and maintains stable output for the microgrid. Figure 1 illustrates the block diagram of the system.




Figure 1: *Proposed block diagram*

3.2 Functionality

LabVIEW's virtual instruments (VIs) provide functions for real-time data acquisition, charge/discharge management, and threshold-based alerts. The proposed system also includes predictive maintenance features, using LabVIEW's analytical tools to assess battery degradation and recommend necessary actions before critical faults occur.

- **SOC Computation Module:** LabVIEW calculates the State of Charge (SOC) in real time by monitoring battery voltage, current, and temperature. This module helps determine battery capacity and guides further operations.
- **Battery Mode Identification:** LabVIEW determines the battery mode (charging, discharging, idle) based on SOC and load demand. Decision-making structures in LabVIEW set these modes dynamically.
- **Closed-Loop Control:** LabVIEW's PID toolkit implements a feedback loop to maintain stable battery operation, adjusting charging and discharging rates in real time to prevent overcharging or over-discharging.
- **Converter:** LabVIEW generates control signals (e.g., PWM) to regulate the converter, adjusting battery output to match load requirements on the DC bus bar.
- **DC Bus Bar:** LabVIEW manages power flow on the DC bus, ensuring balanced distribution to various DC loads and visualizing energy flow within the microgrid.
- **Battery and DC Loads:** LabVIEW monitors battery and load parameters, optimizing power flow. The system can prioritize loads when SOC is low, maintaining essential operations.



4 Results and Discussion

The developed LabVIEW-based BMS was tested on a microgrid model, demonstrating improved battery performance under varying load conditions. Key results include:

- Real-time Monitoring: The system provided accurate and consistent SOC readings, maintaining efficiency and ensuring continuous energy availability.

- Fault Detection and Alerting: Over-temperature conditions triggered automatic alerts and corrective actions, preventing battery health.

- Optimization: Charge cycles were optimized to reduce degradation, extending the battery life by approximately 20%.

These results indicate that LabVIEW provides a robust solution for BMS in microgrids balancing performance with cost-effectiveness.

5 Conclusions

The study on “Battery Management in Microgrid using LabVIEW Software” underscores the potential of utilizing LabVIEW as an efficient and cost-effective platform for real-time battery management in microgrid applications. With the increasing reliance on renewable energy sources, microgrids must have reliable, adaptable battery management systems (BMS) to maintain energy stability and efficiency. Traditional BMS solutions often require significant hardware and software investments, which can limit their application in smaller or distributed energy networks. However, this paper demonstrates that LabVIEW’s versatile graphical programming environment offers an accessible alternative that not only facilitates real-time monitoring and control but also enhances the reliability and performance of battery systems in microgrids. Future work could explore the integration of artificial intelligence and machine learning algorithms within the LabVIEW environment to enable predictive analytics and further enhance the system’s decision-making capabilities. This would allow the BMS to anticipate potential issues based on historical data usage patterns, contributing to proactive maintenance strategies. Additionally, expanding this model for interoperability within larger smart grid systems would facilitate a more resilient and responsive energy infrastructure, enhancing both the efficiency and sustainability of power management at a broader scale.

References

1. L. Roiné; K. Therani; Y. Sahraei Manjili; M. Jamshidi, Year: 2014, "Microgrid energy management system using fuzzy logic control," 2014 World Automation Congress (WAC), Waikoloa, HI, USA, pp. 462-467, doi: 10.1109/WAC.2014.6936001.
2. A. AbouArkoub; M. Soliman Z. Gao; S. Suh; V. D. Perera, Year: 2018, "An Online Smart Microgrid Energy Monitoring and Management System," 2018 IEEE International Conference on Smart Energy Grid Engineering (SEGE), Oshawa, ON, Canada, pp. 58-61.
3. C. Lebrón; F. Andrade; E. O'Neill; A. Irizarry, Year: 2016, "An intelligent Battery management system for home Microgrids," 2016 IEEE Power & Energy Society Innovative Smart Grid Technologies



- Conference (ISGT), Minneapolis, MN, USA, pp. 1-5, doi: 10.1109/ISGT.2016.7781249.
4. L. Guo; N. M. M. Abdul; M. Vengalil; K. Wang; A. Santuzzi, Year: 2022, "Engaging Renewable Energy Education Using a Web-Based Interactive Microgrid Virtual Laboratory," in IEEE Access, Vol. 10, pp. 60972-60984, doi: 10.1109/ACCESS.2022.3181200.
 5. P. Mahat; J. E. Jiménez; E. R. Moldes; S. I. Haug; I. G. Szczesny; K. E. Pollestad; L. C. Totu, Year: 2013, "A micro-grid battery storage management," 2013 IEEE Power & Energy Society General Meeting, Vancouver, BC, Canada, pp. 1-5, doi: 10.1109/PESMG.2013.6672497.
 6. I. Poonahela; S. Bayhan, Year: 2018, "Development of LabVIEW based monitoring system for AC microgrid systems," 2018 IEEE 12th International Conference on Compatibility, Power Electronics and Power Engineering (CPE-POWERENG 2018), Doha, Qatar, pp. 1-6, doi: 10.1109/CPE.2018.8372604.
 7. K. Prompinit; S. Khomfoi, Year: 2018, "Battery Management System for Microgrid Applications," 2018 15th International Conference on Electrical Engineering/Electronics, Computer, Telecommunications and Information Technology (ECTI-CON), Chiang Rai, Thailand, pp. 245-248, doi: 10.1109/ECTICon.2018.8619879.
 8. C. Lebrón; F. Andrade; E. O'Neill; A. Irizarry, Year: 2016, "An intelligent Battery management system for home Microgrids," 2016 IEEE Power & Energy Society Innovative Smart Grid Technologies Conference (ISGT), Minneapolis, MN, USA, pp. 1-5, doi: 10.1109/ISGT.2016.7781249.
 9. A. AbouArkoub; M. Soliman; Z. Gao; S. Suh; V. D. Perera, Year: 2018, "An Online Smart Microgrid Energy Monitoring and Management System," 2018 IEEE International Conference on Smart Energy Grid Engineering (SEGE), Oshawa, ON, Canada, pp. 58-61.
 10. K. Prompinit; S. Khomfoi, Year: 2018, "Battery Management System for Microgrid Applications," 2018 15th International Conference on Electrical Engineering/Electronics, Computer, Telecommunications and Information Technology (ECTI-CON), Chiang Rai, Thailand, pp. 245-248, doi: 10.1109/ECTICon.2018.8619879.
 11. C. Ju; P. Wang, Year: 2016, "Energy management system for microgrids including batteries with degradation costs," 2016 IEEE International Conference on Power System Technology (POWERCON), Wollongong, NSW, Australia, pp. 1-6, doi: 10.1109/POWERCON.2016.7754011.